

# **CITY OF LINCOLN CHILD CARE/PRESCHOOL APPLICANTS**

## **INFORMATION REGARDING CARBON MONOXIDE DETECTORS**

The City of Lincoln adopted the 2012 Edition of the International Fire Code in late 2015. A major change in the fire codes was the requirement for Carbon Monoxide Detectors in Group I or R occupancies (Institutions (Daycares) and Residential) located in buildings which has an attached garage or fuel-burning appliances.

The fire code requires the primary power supply for the CO detectors to be utility power and secondary power is typically a battery. Utility power may be either hardwired or plug-in to an electric wall outlet receptacle. Need CO detector(s) in places where everyone can hear.